

# Indiana Department of Natural Resources / Division of Water

## Record of Water Well

<b>Reference Number</b>	<b>Driving Directions To Well</b>		<b>Date Completed</b>
54028			Nov 7, 1970
<b>Owner/Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Well Owner	Ex. 6 personal	Ex. 6 personal	
Building Contractor			
Drilling Contractor	HAMILTON BROS INC.		
Equipment Operator	TERRY HAMILTON	License:	
<b>Construction Details</b>			
Well	Use: Home	Drilling method: Rotary	Pump type:
	Depth: 59.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 57.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length: 2.0 ft.	Material:	Diameter: 3.00 in. Slot Size: #6
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 2.0 hrs.	Bail test rate:
	Drawdown:	Static water level:	
Grouting Information	Material:		Depth:
	Installation method:		Number of bags used:
Well Abandonment	Sealing Material:		Depth:
	Installation method:		Number of bags used:
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: SE of the SW of the NW of Section 5		Topo map: Indianapolis West
	Field located by: MCBN	On: 1/1/1992	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. accpt. w/o ver. by:	On:	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation: 718.0	Depth to bedrock:	Ft S of NL:
	UTM Easting: 565960.0		Aquifer elevation: 658.0
		UTM Northing: 4402625.0	
Well Log	Top	Bottom	Formation
	0	30	CLAY
	30	40	SAND
	40	57	CLAY
	57	60	SAND
Comments			

# Indiana Department of Natural Resources / Division of Water

## Record of Water Well

<b>Reference Number</b>	<b>Driving Directions To Well</b>	<b>Date Completed</b>
56682	.5 MI W OF GASOLINE ALLEY ON COSSELL RD ON S SIDE (WHERE COSSELL RD DEAD ENDS AT HOLT RD) (4017 COSSELL RD)	Oct 5, 1993

<b>Owner/Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Well Owner	Ex. 6 personal privacy		( )241-6027
Building Contractor			
Drilling Contractor	PERRY WELL DRILLING	4946 SR 32 W ANDERSON IN 46011	( )642-7105
Equipment Operator	JEFF FLEMING	License: 1074	

### Construction Details

Well	Use: Home	Drilling method: Rotary	Pump type: Submersible
	Depth: 260.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 139.0 ft.	Material: PVC	Diameter: 5.00 in.
Screen	Length:	Material:	Diameter: Slot Size:

### Well Capacity Test

Type of test: Air	Test rate: 15.0 gpm for 1.0 hrs.	Bail test rate:
Drawdown:	Static water level: 71.0 ft.	

### Grouting Information

Material: BNSL	Depth: 25.0 to 80.0 ft.
Installation method: TREM	Number of bags used: 2.25

### Well Abandonment

Sealing Material:	Depth: \
Installation method:	Number of bags used:

### Administrative

County: Marion	Township: 15N	Range: 3E
Section: NW of Section 5		Topo map: Maywood
Field located by:	On:	Grant Name:
Courthouse loc. by:	On:	Grant No.:
Loc. accpt. w/o ver. by:	On:	
Subdivision name:	Lot number:	
Ft W of EL:	Ft N of SL:	Ft E of WL:
Ground elevation:	Depth to bedrock:	Ft S of NL:
UTM Easting:		Aquifer elevation:
	UTM Northing:	

### Well Log

Top	Bottom	Formation
0	3	TOP SOIL
3	37	S & G
37	44	GRAY CLAY
44	49	S & G
49	67	GRAY CLAY
67	70	S & G
70	78	GRAY CLAY
78	136	BLK SHALE
136	260	STONE

### Comments

# Indiana Department of Natural Resources / Division of Water

## Record of Water Well

<b>Reference Number</b>	<b>Driving Directions To Well</b>	<b>Date Completed</b>
180236	4019 W COSSELL RD, INDPLS IN 46222.	Sep 5, 1975

<b>Owner/Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor	CLAYTON OTTINGER	RR#3, BOX 162, ZIONSVILLE IN 46077	
Equipment Operator	WM STOVALL	License:	

### Construction Details

Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 41.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 41.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length:	Material:	Diameter: Slot Size: #40 COOKS

### Well Capacity Test

Type of test: Pumping	Test rate: 10.0 gpm for 2.0 hrs.	Bail test rate:
Drawdown: 8.0 ft.	Static water level: 22.0 ft.	

### Grouting Information

Material:	Depth:
Installation method:	Number of bags used:

### Well Abandonment

Sealing Material:	Depth:
Installation method:	Number of bags used:

### Administrative

County: Marion	Township: 15N	Range: 3E
Section: NE of the SW of Section 5		Topo map: Indianapolis West
Field located by:	On:	Grant Name:
Courthouse loc. by:	On:	Grant No.:
Loc. accpt. w/o ver. by: TMB	On: 9/15/1975	
Subdivision name:	Lot number:	
Ft W of EL:	Ft N of SL:	Ft E of WL:
Ground elevation:	Depth to bedrock:	Bedrock elevation:
UTM Easting:		UTM Northing:
		Ft S of NL:
		Aquifer elevation:

### Well Log

Top	Bottom	Formation
0	6	BR CLAY
6	15	DRY GRAV
15	18	BR CLAY & GRAV
18	23	SAND WATER
23	25	GRAY CLAY
25	41	WATER GRAV

### Comments

# Indiana Department of Natural Resources / Division of Water

## Record of Water Well

<b>Reference Number</b>	<b>Driving Directions To Well</b>		<b>Date Completed</b>
180241			Jan 30, 1973
<b>Owner/Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor	HAMILTON BROS INC		
Equipment Operator	RASH	License:	
<b>Construction Details</b>			
Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth: 51.0 ft.	Pump setting depth:	Water quality:
Casing	Length: 51.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length: 3.0 ft.	Material:	Diameter: 4.00 in. Slot Size:
Well Capacity Test	Type of test:	Test rate:	Bail test rate: 10.0 gpm for 5.0 hrs.
	Drawdown:	Static water level:	
Grouting Information	Material:	Depth:	
	Installation method:	Number of bags used:	
Well Abandonment	Sealing Material:	Depth:	
	Installation method:	Number of bags used:	
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: 5		Topo map: Indianapolis West
	Field located by:	On:	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. acpt. w/o ver. by:	On:	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:
	UTM Easting:		UTM Northing:
Well Log	Top	Bottom	Formation
	0	5	TOPSOIL & CLAY
	5	35	SAND
	35	51	CLAY
Comments			

# Indiana Department of Natural Resources / Division of Water

## Record of Water Well

<b>Reference Number</b>	<b>Driving Directions To Well</b>		<b>Date Completed</b>
180590	BETWEEN REONA & HOLT RD. OFF MICHIGAN		Oct 28, 1979
<b>Owner/Contractor</b>	<b>Name</b>	<b>Address</b>	<b>Telephone</b>
Well Owner	Ex. 6 personal privacy		
Building Contractor			
Drilling Contractor			
Equipment Operator	JOHN AUFDERHEIDE	License:	
<b>Construction Details</b>			
Well	Use: Home	Drilling method: Cable Tool	Pump type:
	Depth:	Pump setting depth: 40.0 ft.	Water quality: CLEAR
Casing	Length: 50.0 ft.	Material:	Diameter: 4.00 in.
Screen	Length: 5.0 ft.	Material:	Diameter: 3.00 in. Slot Size: 30
Well Capacity Test	Type of test: Bailing	Test rate: 10.0 gpm for 1.0 hrs.	Bail test rate:
	Drawdown: 12.0 ft.	Static water level: 23.0 ft.	
Grouting Information	Material:		Depth:
	Installation method:		Number of bags used:
Well Abandonment	Sealing Material:		Depth:
	Installation method:		Number of bags used:
Administrative	County: Marion	Township: 15N	Range: 3E
	Section: SE of the NW of Section 5		Topo map: Indianapolis West
	Field located by:	On:	Grant Name:
	Courthouse loc. by:	On:	Grant No.:
	Loc. acpt. w/o ver. by: TCS	On:	
	Subdivision name:	Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:
	UTM Easting:		UTM Northing:
Well Log	Top	Bottom	Formation
	0	10	CLAY
	10	35	SAND & GRAVEL
	35	45	CLAY
	45	49	SOUPY SAND
	49	52	SAND & GRAVEL
Comments			